



NOTE:

1. EXTEND ENCASEMENT AT PIPE CROSSINGS 10 FEET IN EACH DIRECTION.

PIPE ENCASEMENT  
NOT TO SCALE

2525

UPPER THOMPSON  
SANITATION DISTRICT  
PIPE ENCASEMENT  
STANDARD DETAIL NO. 2525



Upper Thompson Sanitation District  
2196 Mall Road  
Estes Park, Colorado 80517  
Phone: 970.586.4544