



NOTES:

1. ALL CLEANOUTS SHALL HAVE FEMALE IRON PIPE THREADS X SEWER HUB ADAPTER WITH RAISED MALE IRON PIPE THREAD. CAP SHALL NOT PROJECT MORE THAN 2".
2. ALL WYES SHALL ALLOW FOR UPSTREAM ACCESS OF UNDERDRAIN.
3. ALL PVC PIPE SHALL BE SCHEDULE 80 PVC.
4. SEE DETAIL 2610 FOR ADDITIONAL MANHOLE DETAILS.

MANHOLE WITH UNDERDRAIN

NOT TO SCALE

2611

