



NOTES:  
 1. PROVIDE PROTECTIVE COATING TO EXTERIOR SURFACES OF VALVE BODY, VALVE BOX, EXTENSION STEM AND APPURTENANCES.  
 2. SEE DETAIL 2660 FOR VALVE MARKER.

**BURIED VALVE**  
 NOT TO SCALE

**BURIED VALVE INSTALLATION**

**2635**

